


NOTES:

1. SYSTEM DESIGN ENGINEER MUST SIZE BYPASS LINE BETWEEN HEATING SYSTEM SUPPLY AND RETURN TO ENSURE THAT RETURN WATER TEMPERATURES TO CONVENTIONAL HIGH MASS NON-CONDENSING BOILERS ALWAYS REMAINS ABOVE 140°F
2. REFER TO SMARTPLATE INSTALLATION DRAWINGS FOR RECOMMENDED DOMESTIC PIPING INSTALLATION.

- SD-A-772
- SD-A-773
- SD-A-774
- SD-A-775
- SD-A-776
- SD-A-777

 <b>AERCO INTERNATIONAL, INC.</b> <small>Blauvelt, NY 10913</small>	
<b>SMARTPLATE</b> MULTIPLE UNITS WITH CONVENTIONAL HEATING SYSTEM AS A ZONE	
DWN. BY <u>K.S.</u> DATE <u>011713</u> SCALE <u>NTS</u> APPD. _____ DATE _____	REV. <b>C</b> <b>SD-A-784</b>